

SPECIAL METHODIC OF ECONOMICS INDEXES DETERMINATION OF TURBOCOMPRESSOR STATIONS FOR CENTRAL AIR SUPPLY OF INDUSTRIAL FACTORIES

© 2009 D. A. Dovgyallo, V. A. Kudinov

Samara state technical university

In this paper it is presented recommendations of using of compressor stations working parameters and their external output characteristics to evaluate of energy saving reserves during work on non standard regime.

Turbo compressor, air production, energy unit costs, plant work data

Dovgyallo Danila Aleksandrovich, post-graduate student of department heat engineering theory and hydromechanics, Samara state technical university. Phone: (927) 713-95-39. E-mail: dovdan@mail.ru. Area of research: heat and cooling machines' work processes, energy saving.

Kudinov Vasiliy Aleksandrovich, doctor of physico-mathematical science, professor of department heat engineering theory and hydromechanics of Samara state technical university. Phone: (846) 332-42-44, 332-42-35. E-mail: totig@yandex.ru. Area of research: mathematical methods and mathematical simulation, thermal power plant work processes, energy saving.

References

1. Minyaev Y.N. Energy investigation of industrial factories' pneumo devices. – Ekaterinburg, 2003. - 151 p.
2. Nazarenko U. P. Electro energy economy in production and using of pressed air – M.: Energy, 1976. – 104 p.
3. Seleznev K.P., Galerkin and other. Theory and calculation of turbo compressors.– L.: Mashinostroenie, 1986. – 392 p.